

# Confined Space Register 2012

Original assessment by AECOM Australia Pty Ltd

### A=COM

# Magill

# **Building TG**

#### **Version 1**

Note: document links in blue underline text Symbols on plans are also links

Version No.	Date	Amendment details	Approved by
1	25/09/2012	Original version as assessed by AECOM Australia Pty Ltd	-

This Confined Space Register does not remove the requirement for contractors to complete their own work-based risk assessment.

Please refer to Appendix for other spaces assessed.



AECOM's assessment of a confined space was based on the information provided by the University of South Australia (UniSA) site representative and visual observation on the day. Risk assessment and hazard identification of a confined space was classified in accordance with:

- Work Health and Safety Regulations 2012 (SA);
- AS2865-2009.

Should UniSA wish to declassify a space which AECOM has deemed to be a 'Confined Space', section 2.4.6 of AS 2865-2009 must be adhered to as stated below.

"For a space which has previously been classified as a confined space to be reclassified as a non-confined space, it needs to have undergone sufficient changes in structure or usages to eliminate (without the need for risk control measures) all possible sources of inherent hazard that define a confined space. Any changes to a confined space would have to be such that a subsequent risk assessment would determine that it no longer meets the criteria for a confined space".

Sufficient evidence to show that the statement above has been met must be provided to the University of South Australia Facilities Management Unit who has the appropriate privilege to alter the Confined Space Register.



#### Confined Space Register 2012

Assessed by AECOM Australia Pty Ltd, June to December 2012

Magill

Building TG

Version 1

			Confined Space according to Work Health and Safety	Confined Space				
Space ID	Space description	Location	Regulations	according to AS 2865-2009?	UniSA deemed Confined Space?	Comments	ink to letails	Link to Plan

No Confined Spaces assessed



All drawings remain the property of the University of South Australia and must be returned upon request.
These drawings are subject to change without notice.
Any errors and/or omissions should be reported to the
Facilities Management Unit.

## **LEGEND**

RED Deemed Confined Space

GREEN Deemed Non-Confined Space

1

ROOM



ABOVE OR BELOW CURRENT LEVEL



WITHIN ROOM



ACCESS TO ABOVE



ACCESS TO BELOW



ACCESS DIRECTION (relative to plan)



**FACILITIES MANAGEMENT** UNIT

Level 2, 101 Currie Street, Adelaide. SA 5000 Phone 8302 2762 Fax 8302 2708

#### **CONFINED SPACE**

MAGILL CAMPUS

Building

# **BUILDING TG** LEVEL 01

Scale:	Drawn:
Not to scale	SMG
Last Update:	Plot Date:
14/01/2013	06/09/2012 08:49



Drawing No.:

Revision:

H337CS01



# Appendix Register of other spaces assessed

# Magill

# **Building TG**

This Register does not remove the requirement for contractors to complete their own work-based risk assessment.



Register of other spaces assessed
Assessed by AECOM Australia Pty Ltd, June to December 2012
Magill
Building TG

Version 1

Space ID	Space description	Location	Confined Space according to Work Health and Safety Regulations 2012 (SA)?	Confined Space according to AS 2865-2009?	UniSA deemed Confined Space?	Comments	Link to details	Link to Plan
MG-TG-01	Garage	TG1-01	No	No	Non-Confined Space	This is a restricted Space	MG-TG-01	Level 1

#### University of South Australia Confined Space Register 2012

Assessed by: AECOM Australia Pty Ltd

Campus:	Magill	Date Assessed:	25/09/2012	
Building:	TG	Assessors:	Daniel Alexander	
Space ID:	MG-TG-01	UniSA deemed:	New Confined Space	
Description:	Garage	Unisa deemed:	Non-Confined Space	
Location:	TG1-01	UniSA deems a space Confined Space if either assessment criteria (shown below) results in Yes.		

Number of Entrances:	1
Entry type:	Door / Gate
Access type:	Easy access

Comments:	This is a restricted Space
Additional Hazards:	

#### View on plan

Category	Criteria: Work Health and Safety Regulations 2012 (SA)	Result
А	Is the space enclosed or partially enclosed?	Yes
В	Is not designed or intended primarily to be occupied by a person?	No
С	ls, or is designed or intended to be, at normal atmospheric pressure while any person is in the space?	Yes
D	Is or is likely to be a risk to health and safety from:	
i)	an atmosphere that does not have a safe oxygen level?	No
ii)	contaminants, including airborne gases, vapours and dusts, that may cause injury from fire or explosion?	No
iii)	harmful concentrations of any airborne contaminants?	No
iv)	engulfment?	No
Confined Space	If the answer to A <b>and</b> B <b>and</b> C <b>and</b> at least one of D i), ii), iii) or iv) is Yes, then the space is a Confined Space.	No

		1/4
Serion		
	Harden Company	

#### Return to Register

Category	Criteria: AS2865-2009	Result
А	Is the space enclosed or partially enclosed?	Yes
В	Is not intended or designed primarily for human occupancy?	Yes
С	Has an oxygen concentration outside the safe oxygen range?	No
D	Has a concentration of airborne contaminant that may cause impairment, loss of consciousness or asphyxiation?	No
Е	Has a concentration of flammable airborne contaminant that may cause injury from fire or explosion?	No
F	Has a risk of engulfment in a stored free flowing solid or a rising level of liquid that may cause suffocation or drowning?	No
Confined Space	If the answer to A <b>and</b> B <b>and</b> at least one of C, D, E or F is Yes, then the space is a Confined Space.	No

Date	Amendment details	Approved by

