

# Confined Space Register 2012

Original assessment by AECOM Australia Pty Ltd

### A=COM

### **Mawson Lakes**

### **Building SB**

### **Version 1**

Note: document links in blue underline text Symbols on plans are also links

Version No.	Date	Amendment details	Approved by
1	13/09/2012	Original version as assessed by AECOM Australia Pty Ltd	-

This Confined Space Register does not remove the requirement for contractors to complete their own work-based risk assessment.

Please refer to Appendix for other spaces assessed.



AECOM's assessment of a confined space was based on the information provided by the University of South Australia (UniSA) site representative and visual observation on the day. Risk assessment and hazard identification of a confined space was classified in accordance with:

- Work Health and Safety Regulations 2012 (SA);
- AS2865-2009.

Should UniSA wish to declassify a space which AECOM has deemed to be a 'Confined Space', section 2.4.6 of AS 2865-2009 must be adhered to as stated below.

"For a space which has previously been classified as a confined space to be reclassified as a non-confined space, it needs to have undergone sufficient changes in structure or usages to eliminate (without the need for risk control measures) all possible sources of inherent hazard that define a confined space. Any changes to a confined space would have to be such that a subsequent risk assessment would determine that it no longer meets the criteria for a confined space".

Sufficient evidence to show that the statement above has been met must be provided to the University of South Australia Facilities Management Unit who has the appropriate privilege to alter the Confined Space Register.



### Confined Space Register 2012

Assessed by AECOM Australia Pty Ltd, June to December 2012

Mawson Lakes

Building SB

Version 1

			Confined Space according to Work Health and Safety	Confined Space				
Space ID	Space description	Location	Regulations	according to AS 2865-2009?	UniSA deemed Confined Space?	Comments	Link to details	Link to Plan

No Confined Spaces assessed

BUILDING M

All drawings remain the property of the University of South Australia and must be returned upon request.
These drawings are subject to change without notice.
Any errors and/or omissions should be reported to the
Facilities Management Unit. **LEGEND** RED Deemed Confined Space GREEN Deemed Non-Confined Space 1 ROOM (1) ABOVE OR BELOW CURRENT LEVEL WITHIN ROOM ACCESS TO ABOVE ACCESS TO BELOW



ACCESS DIRECTION (relative to plan)

**FACILITIES MANAGEMENT** UNIT

Level 2, 101 Currie Street, Adelaide. SA 5000 Phone 8302 2762 Fax 8302 2708

### **CONFINED SPACE**

MAWSON LAKES CAMPUS

Building

**BUILDING SB** LEVEL 01

Scale:	Drawn:
Not to scale	SMG
Last Update:	Plot Date:
22/01/2013	06/09/2012 08:49



Drawing No.: H542CS01

Revision:

# Appendix Register of other spaces assessed

### **Mawson Lakes**

## **Building SB**

This Register does not remove the requirement for contractors to complete their own work-based risk assessment.



Register of other spaces assessed
Assessed by AECOM Australia Pty Ltd, June to December 2012
Mawson Lakes
Building SB

Version 1

Space ID	Space description	Location	Confined Space according to Work Health and Safety Regulations 2012 (SA)?	Confined Space according to AS 2865-2009?	UniSA deemed Confined Space?	Comments	Link to details	Link to Plan
ML-SB-01	Storage Containers x 2	SB1-01	No	No	Non-Confined Space	This is a restricted space	ML-SB-01	Level 1

### University of South Australia Confined Space Register 2012

Assessed by: AECOM Australia Pty Ltd

Description:	Storage Containers x 2	
Space ID:	ML-SB-01	
Building:	SB	
Campus:	Mawson Lakes	

SB1-01

Location:

Date Assessed: 13/09/2012 Assessors: Daniel Alexander

nis A doomad:	Non Confined Space

UniSA deems a space Confined Space if either assessment criteria (shown below) results in Yes.

Number of Entrances:	1
Entry type:	Door / Gate
Access type:	Easy access

Comments:	This is a restricted space
Additional Hazards:	Mechanical

	on	

Category	Criteria: Work Health and Safety Regulations 2012 (SA)	Result		
А	Is the space enclosed or partially enclosed?	Yes		
В	Is not designed or intended primarily to be occupied by a person?			
С	ls, or is designed or intended to be, at normal atmospheric pressure while any person is in the space?			
D	Is or is likely to be a risk to health and safety from:			
i)	an atmosphere that does not have a safe oxygen level?	No		
ii)	contaminants, including airborne gases, vapours and dusts, that may cause injury from fire or explosion?	No		
iii)	harmful concentrations of any airborne contaminants?	No		
iv)	engulfment?	No		
Confined Space	If the answer to A <b>and</b> B <b>and</b> C <b>and</b> at least one of D i), ii), iii) or iv) is Yes, then the space is a Confined Space.	No		

### Return to Register

Category	Criteria: AS2865-2009	Result
А	Is the space enclosed or partially enclosed?	Yes
В	Is not intended or designed primarily for human occupancy?	No
С	Has an oxygen concentration outside the safe oxygen range?	No
D	Has a concentration of airborne contaminant that may cause impairment, loss of consciousness or asphyxiation?	No
Е	Has a concentration of flammable airborne contaminant that may cause injury from fire or explosion?	No
F	Has a risk of engulfment in a stored free flowing solid or a rising level of liquid that may cause suffocation or drowning?	No
Confined Space	If the answer to A <b>and</b> B <b>and</b> at least one of C, D, E or F is Yes, then the space is a Confined Space.	No

			7 3
	I		
	-	le January	

Date	Amendment details	Approved by

